



中国认可
国际互认
检测
TESTING
CNAS L4638



真伪查询

180008223339 (2018) 国认监认字 (509) 号

检 测 报 告

Test Report

报告编号:

Report No. WFM202004076A

样品名称:

Name of products

黄铜Y型过滤器

委托单位:

Applicant entity

科诺威德 (集团) 有限公司

生产单位:

Manufacturer

科诺威德 (集团) 有限公司

检测类别:

Test type

委托检测

浙江省泵阀产品质量检验中心

Quality Inspection Center of Pump and Valve Products of Zhejiang Province

国家阀门质量监督检验中心 (浙江)

National Quality Supervision and Inspection Center of Valve Products (Zhejiang)

浙江省泵阀产品质量检验中心
国家阀门质量监督检验中心（浙江）
检 测 报 告

报告编号：WFM202004076A


共 2 页 第 1 页

样品名称	黄铜Y型过滤器	型号规格	GL11W-16T DN20
委托单位	科诺威德（集团）有限公司	地址	浙江省温州市乐清市北白象镇 温州大桥工业园区
受检单位	/	地址	/
生产单位	科诺威德（集团）有限公司	地址	浙江省温州市乐清市北白象镇 温州大桥工业园区
检测类别	委托检测	商标	/
生产日期	/	样品状况	合格品
阀体材料	/	炉号/锻打批号	/
样品数量	1 台	样品编号	WFM202004076/001
送样单位	科诺威德（集团）有限公司	到样日期	2020年04月17日
检测地点	检测中心	检测日期	2020年05月06日
检测依据	GB/T 13927-2008 《工业阀门 压力试验》		
检测项目	壳体试验。		
检测结论	该样品所检项目检测结果符合标准要求。  签发日期：2020年06月12日		
备注	该报告代替WFM202004076, 原报告作废。		

批准：




审核：



编制：



浙江省泵阀产品质量检验中心 国家阀门质量监督检验中心（浙江） 阀门检测报告			报告编号：WFM202004076A	
			共 2 页	第 2 页
检测项目	标准要求		检测结果	判定
壳体试验 (介质：水)	试验压力	2.4 MPa	2.40 MPa	合格
	持续时间	≥15 s	15 s	
	结果	无可见渗漏 及结构损伤	无可见渗漏 及结构损伤	
样品照片				
				

浙江省泵阀产品质量检验中心
用章

注 意 事 项

REMARKS

- 1、报告无编制、审核、批准人签字无效。
Report is invalid without signatures by concerning persons of issuing, auditing and approvement.
- 2、报告由计算机打印输出，涂改无效。
Report is output by the computer, and alteration is invalid.
- 3、报告(复印件)未加盖本单位红色检验检测专用章无效。
Report or copy is invalid without the red special test seal.
- 4、委托方若对报告有异议，应及时向本单位提出。
Any dissent of inspection report should be proposed by applicant timely.
- 5、一般情况下，委托检测的结果仅对本次受检验样品有效。
Generally, the report takes responsibility only for the tested samples tested.
- 6、中文与英文解释有差异的，以中文为准。
If discrepancy exists between the Chinese and English explanations of the report, the Chinese version shall prevail.
- 7、报告盖章处：封面、签发、骑缝。
Report Seal: Cover, Issuance, Across-page seal.

地址：浙江省永嘉县瓯北镇东瓯工业园区五星大道质检大楼

Address: Quality Supervision Building, Wuxing Avenue, Dong'ou Industrial Park, Oubei Town, Yongjia County, Zhejiang Province

电 话 (Tel) : 0577-67927808

传 真 (Fax) : 0577-67927826

邮政编码 (Post) : 325105

电子信箱 (E-mail) : yjzjsb@126.com



微信公众号